

**CITY OF SHEPHERDSVILLE ORDINANCE NO. 012-119**

**AMENDMENT TO CITY OF SHEPHERDSVILLE  
SEWER USE ORDINANCE NO. 992-275**

**THE CITY COUNCIL OF THE CITY OF SHEPHERDSVILLE, KENTUCKY DOES  
ORDAIN AS FOLLOWS:**

WHEREAS, it is necessary to amend and reenact certain sections of the City of Shepherdsville Sewer Use Ordinance No. 992-275, said ordinance is hereby amended to read as follows:

**ARTICLE I - GENERAL PROVISIONS**

**B. Definitions**

69. Significant Industrial User (SIU). Defined by EPA guidance regulations as: (A) all industrial users subject to Categorical Pretreatment Standards under 40 CFR 403.6 and 40 CFR Chapter I, Subchapter N; and (B) any noncategorical user that (i) discharges 25,000 gallons per day or more of process wastewater ("process wastewater" excludes sanitary, noncontact cooling, and boiler blowdown wastewaters) or (ii) contributes a process wastestream which makes up five percent or more of the average dry weather hydraulic or organic (BOD, TSS, etc.) capacity of the treatment plant or (iii) has a reasonable potential, in the opinion of the Control or Approval Authority, to adversely affect the POTW treatment plant (inhibition, pass through of pollutants, sludge contamination or endangerment of POTW workers) or violate any requirements of this ordinance. The City may determine that an Industrial User subject to categorical Pretreatment Standards is a Non-Significant Categorical Industrial User rather than a Significant Industrial User on a finding that the Industrial User never discharges more than 100 gallons per day (gpd) of total categorical wastewater (excluding sanitary, non-contact cooling and boiler blowdown wastewater, unless specifically included in the Pretreatment Standard) and the following conditions are met: (1) The Industrial User, prior to the City's finding, has consistently complied with all applicable categorical Pretreatment Standards and Requirements; (2) The Industrial User annually submits the certification statement required in 40 CFR 403.12(q) together with any additional information necessary to support the certification statement; and (3) the Industrial User never discharges any untreated concentrated process wastewater.

Upon a finding that a User meeting the criteria in this section has no reasonable potential for adversely affecting the POTW's operation or for violating any Pretreatment Standard or Requirement, the City may at any time, on its own initiative or in response to a petition received from an Industrial User, and in accordance with procedures in 40 CFR 403.8(f)(6), determine that such User should not be considered a Significant Industrial User.

94. Best Management Practices or BMPs. Schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to implement the prohibitions listed in 40 CFR 403.5. BMPs include, but are not limited to, treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw materials storage.

**ARTICLE II - USE OF PUBLIC SEWERS**

**E. Prohibited Discharges:**

No user shall contribute or cause to be contributed, directly or indirectly, any pollutant or wastewater which will interfere with performance of the POTW or cause Pass Through to the receiving stream. These general prohibitions apply to all such users of the POTW whether or not the user is subject to National Categorical Pretreatment Standards or any other National, State, or local Pretreatment Standards or Requirements. A user shall not contribute the following substances to the POTW:

2. Any waters or wastes having a pH lower than 5.0 or higher than ~~9.0~~ 10.0 or having any other corrosive property capable of causing damage or hazard to structures, equipment, and personnel of the POTW.

**ARTICLE V - POLLUTANT DISCHARGE LIMITS**

**B. Restricted Discharges**

11. The following limitations are established for characteristics of any wastewaters to be discharged into the municipal sewer system. All significant industrial users must comply with these limitations where they are more stringent than applicable state and/or Federal regulations. In accordance with 40 CFR 403, these limitations are considered pretreatment standards equivalent to the Federal limitations established in 40 CFR Subchapter N.

<u>Parameter</u>	<u>Maximum Daily Concentration (mg/l)</u>	
Arsenic	5.94	<u>2.40</u>
Cadmium	<del>0.69</del>	<u>0.05</u>
Chromium, <u>Total</u>	2.77	
<u>Chromium, Hexavalent</u>		<u>0.86</u>
Copper	3.38	
Cyanide, <u>Total Amenable</u>	4.12	<u>0.60</u>

